



CONFINED SPACE PERMIT

Generated by Safety Compliance App www.safetycompliance.com | www.safetycomplianceapp.com

Company	Bay City Boiler	Project	UC Davis
Time	09:38 AM	Date	April 26, 2024
Duration	07	Supervisor Name	Tony Baxter

SECTION 1

SITE LOCATION

Boiler 3 fire box

DESCRIPTION OF CONFINEDSPACE

Checking tube repair hydro

NATURE OF WORK/ REASON FOR ENTRY

Looking inspection

OTHER PERMITS

1 # Hot Permit 1

SECTION 2

PERMIT PULLED

Pull Date : **April 26, 2024**

Pull Time : **09:38 AM**

Pull Duration : **07**

PERMIT CLOSED

Closed Date : **April 26, 2024**

Closed Time : **02:34 PM**

RESCUE AND EMERGENCY RESPONSE

No Entry Rescue

Hole watch only

SECTION 3

Atmospheric Hazard Identification

Air Monitoring location specified **Bottom**

Air Monitoring location specified **Opening**

Ventilation

Adequate pre-entry ventilation has been completed **NATURAL**

SECTION 4

INITIAL TEST BEFORE MECHANICAL VENTILATION OR ENTRY

LEL	0
Oxygen	20.9
H2S	0
CO	0

COMMUNICATION SYSTEM

Radio

Verbal

Sight

Phone

OTHER HAZARDS

Poor Lighting

PPE REQUIRED

Head Protection

Eye Protection

Respiratory Protection

Body Protection

SUPERVISOR SIGNATURE

A handwritten signature consisting of a single, fluid stroke that forms a stylized letter 'A' with a loop at the bottom.

CLOSED SIGNATURE

A handwritten signature consisting of a single, fluid stroke that forms a stylized letter 'A' with a loop at the bottom, identical to the one above.