



# CONFINED SPACE PERMIT

Generated by Safety Compliance App [www.safetycompliance.com](http://www.safetycompliance.com) | [www.safetycomplianceapp.com](http://www.safetycomplianceapp.com)

<b>Company</b>	Bay City Boiler	<b>Project</b>	UC Davis
<b>Time</b>	12:53 PM	<b>Date</b>	April 30, 2024
<b>Duration</b>	04	<b>Supervisor Name</b>	Tony Baxter

## SECTION 1

### SITE LOCATION

Boiler 3

### DESCRIPTION OF CONFINEDSPACE

Tube repair Refractory

### NATURE OF WORK/ REASON FOR ENTRY

Repair tube inspect Refractory

### OTHER PERMITS

**1 # Hot Permit 1**

## SECTION 2

### PERMIT PULLED

Pull Date : **April 30, 2024**

Pull Time : **12:53 PM**

Pull Duration : **04**

### PERMIT CLOSED

Closed Date : **April 30, 2024**

Closed Time : **03:05 PM**

### RESCUE AND EMERGENCY RESPONSE

**No Entry Rescue**

Visual

## SECTION 3

### Atmospheric Hazard Identification

**Air Monitoring location specified**    **Opening**

### Ventilation

**Adequate pre-entry ventilation has been completed**    **NATURAL**

## SECTION 4

### INITIAL TEST BEFORE MECHANICAL VENTILATION OR ENTRY

LEL	0
Oxygen	20.9
H2S	0
CO	0

## COMMUNICATION SYSTEM

Verbal

Sight

## OTHER HAZARDS

Poor Lighting

Temperature

## PPE REQUIRED

Head Protection

Eye Protection

Respiratory Protection

Body Protection

Fall Protection

## SUPERVISOR SIGNATURE

A handwritten signature consisting of a single, fluid stroke that forms a stylized letter 'A' with a horizontal crossbar.

**CLOSED SIGNATURE**

A handwritten signature consisting of a single, fluid stroke that forms a stylized letter 'A' with a horizontal crossbar, identical to the one above.