



# HOT WORK PERMIT

Generated by Safety Compliance App [www.safetycompliance.com](http://www.safetycompliance.com) | [www.safetycomplianceapp.com](http://www.safetycomplianceapp.com)

|                            |                      |                          |   |
|----------------------------|----------------------|--------------------------|---|
| <b>Company</b>             | Concrete North, Inc. | <b>Project</b>           | 18-008 CSU Stanislaus Student Union<br>Renovation |
| <b>Start Time</b>          | 07:00 AM             | <b>Finish Time</b>       | 02:00 PM  |
| <b>Person Filling Out</b>  | Ruben Ochoa          | <b>Fire Watch Person</b> | Jose Ugalde (CMC)                                 |
| <b>End Fire Watch Time</b> | 02:30 PM             | <b>Work Location</b>     | Topping SOG West Elevation                        |
| <b>Add Date</b>            | March 04, 2019       |                          |   |

=> **Person doing hot work has been trained in the safe use of equipment, and how to work safely**

## QUESTIONS

=> **Fire extinguishers available for immediate use**

=> **Correct type fire extinguishers are available**

=> **Combustible materials and supplies are moved away from the hot work location (at least 35')**

=> **Verify that equipment is not to be used near flammable vapors or liquids, or their containers**

=> **Fire hazards that can't be moved are protected by appropriate guards**

=> **On-site contractors and personnel advised of hot work**

=> **Warning sign(s) posted to warn other workers**

=> **Maintain a fire watch during operations and for at least 30 minutes after work has been completed**

## SIGNATURE