



HOT WORK PERMIT

Generated by Safety Compliance App www.safetycompliance.com | www.safetycomplianceapp.com

Company	Concrete North, Inc.	Project	18-008 CSU Stanislaus Student Union Renovation
Start Time	07:09 AM	Finish Time	02:30 PM
Person Filling Out	Robert Briscese	Fire Watch Person	Alexis Valdovinos
End Fire Watch Time	03:00 PM	Work Location	Existing Bookstore
Add Date	April 24, 2019		

=> Person doing hot work has been trained in the safe use of equipment, and how to work safely

QUESTIONS

=> Fire extinguishers available for immediate use

=> Correct type fire extinguishers are available

=> Floors are swept clean of combustible materials (35' radius)

=> Verify that equipment is not to be used near flammable vapors or liquids, or their containers

=> Dusts and conveyor systems such as duct work that might carry sparks are cleaned, protected and

=> On-site contractors and personnel advised of hot work

=> Warning sign(s) posted to warn other workers

=> Maintain a fire watch during operations and for at least 30 minutes after work has been completed

SIGNATURE

Byba