



PROJECT INSPECTION

Generated by Safety Compliance App www.safetycompliance.com | www.safetycomplianceapp.com

Company	Bay City Boiler	Type of Inspection:	General Construction
Project	Sees Candy El Comino	Date of Inspection	October 21, 2024
Inspector Name	Kevin South	Time of Inspection	10:52 AM

NOTES

19
Items Inspected

8
Satisfactory

0
Unsatisfactory

11
N/A

Troubleshooting call on the CB Boiler. Found bad low water probe connections

INSPECTION ITEMS

General

Is emergency equipment available, including first aid kit(s) and fire extinguisher(s)?

Satisfactory

Is safety documentation available (Written Safety Programs, SDS, Tailgate Meetings)

Satisfactory

Is drinking water and shade set up sufficient for the amount of workers?

Satisfactory

Are emergency and labor law postings in place?

N/A

Is Personal Protective Equipment being worn as required?

Satisfactory

Are scaffolding safety procedures being followed?

N/A

Are hand and power tools being used safely?

Satisfactory

Is good housekeeping being maintained?

Satisfactory

Is fall protection in place where required?	N/A
Is trenching & excavation work being done safely?	N/A
Are confined space safety procedures being followed?	N/A
Are scissor lifts / elevated platforms being used safely?	N/A
Are boom lifts and other aerial devices being used safely?	N/A
Is heavy equipment being used safely?	N/A
Are electrical items being used safely?	Satisfactory
Are roofing operations being performed safely?	N/A
Is demolition work being done safely?	N/A
Are all other tasks being performed safely?	Satisfactory
Any other items?	N/A