



# PROJECT INSPECTION

Generated by Safety Compliance App [www.safetycompliance.com](http://www.safetycompliance.com) | [www.safetycomplianceapp.com](http://www.safetycomplianceapp.com)

<b>Company</b>	Karsyn Construction	<b>Type of Inspection:</b>	Scaffolding
<b>Project</b>	Hirayama Elementary	<b>Date of Inspection</b>	December 06, 2024
<b>Inspector Name</b>	Angel Serafin-Sandoval	<b>Time of Inspection</b>	06:37 AM

## NOTES

15 Items Inspected	15 Satisfactory	0 Unsatisfactory	0 N/A
-----------------------	--------------------	---------------------	----------

## INSPECTION ITEMS

### General

Are daily inspections being done by a competent person? **Satisfactory**

Is the scaffold on a secure foundation? **Satisfactory**

Are base plates installed and appropriately nailed to mud sills (if sills are required)? **Satisfactory**

Is the scaffold plumb and level? **Satisfactory**

Are cross braces installed per the manufacturer and OSHA instructions? **Satisfactory**

Are platforms fully planked with no more than a 1" gap between planks? **Satisfactory**

Are planks in safe condition? **Satisfactory**

Do planks overlap supports (or otherwise secured) per manufacturer and OSHA instructions? **Satisfactory**

**Are guardrails correctly installed on platforms above 6 feet? (Note: Some Mfg's require rails at any height)**

**Satisfactory**

**is there safe access to each working level of the scaffold?**

**Satisfactory**

**Are toe-boards installed where required, including above entranceways and where others may pass underneath?**

**Satisfactory**

**if more than four times the width of the base, is the scaffold braced per the manufacturer and OSHA instructions?**

**Satisfactory**

**Are only trained users being allowed on the scaffold?**

**Satisfactory**

**Are only competent, qualified persons erecting and dismantling scaffolding?**

**Satisfactory**

**Is the scaffold safe to use in every other way?**

**Satisfactory**