

## **PROJECT INSPECTION**

Generated by Safety Compliance App www.safetycompliance.com | www.safetycomplianceapp.com

| Company Ka        | Carsyn Construction    | Type of<br>Inspection: | Cal/OSHA Scaffold |
|-------------------|------------------------|------------------------|-------------------|
| Project Te        | erry Bradley Ed Center | Date of<br>Inspection  | December 11, 2024 |
| Inspector Name Ni | lick Watts             | Time of<br>Inspection  | 02:10 PM          |

| NOTES           |              |                |          |  |  |  |
|-----------------|--------------|----------------|----------|--|--|--|
| 16              | <b>16</b>    | <b>0</b>       | <b>0</b> |  |  |  |
| Items Inspected | Satisfactory | Unsatisfactory | N/A      |  |  |  |

## **INSPECTION ITEMS**

| General  |              |
|--|--------------|
| Are erectors and dismantlers under the supervision of a qualified erector?   | Satisfactory |
| Is the scaffold safe to use in every other way?  | Satisfactory |
| Are only trained users being allowed on the scaffold?  | Satisfactory |
| if more than three times the width of the base, is the scaffold braced per the manufacturer and OSHA instructions? | Satisfactory |
| Are toe-boards installed where required, including above entranceways and where others may pass underneath?        | Satisfactory |
| is there safe access to each working level of the scaffold?  | Satisfactory |
| Are guardrails correctly installed on platforms above 7 1/2 feet? (Note: Some Mfg's require rails at any height)   | Satisfactory |
| Do planks overlap supports (or otherwise secured) per manufacturer and OSHA instructions?                          | Satisfactory |

| Are planks in safe condition?   | Satisfactory |
|---|--------------|
| Are platforms fully planked with no more than a 1" gap between planks?  | Satisfactory |
| Are cross braces installed per the manufacturer and OSHA instructions?  | Satisfactory |
| Is the scaffold plumb and level?  | Satisfactory |
| Are base plates installed and appropriately nailed to mud sills (if sills are required)?  | Satisfactory |
| Is the scaffold on a secure foundation?   | Satisfactory |
| If over 36 feet or 3 stories, has an OSHA permit for scaffolding been pulled and notification of activity given to the local OSHA office? | Satisfactory |
| Are daily inspections being done by a competent person?   | Satisfactory |