



PROJECT INSPECTION

Generated by Safety Compliance App www.safetycompliance.com | www.safetycomplianceapp.com

Company	Thomas James Homes: NorCal	Type of Inspection:	General Construction
Project	18 The Nines Lafayette	Date of Inspection	September 27, 2024
Inspector Name	Joshua Giverink	Time of Inspection	12:14 PM

NOTES

19 Items Inspected	15 Satisfactory	1 Unsatisfactory	3 N/A
-----------------------	--------------------	---------------------	----------

Safety rails removed by AM drywall. They have been notified to have them reinstalled asap. Rest of the site looks to be in good working order

INSPECTION ITEMS

General

Is emergency equipment available, including first aid kit(s) and fire extinguisher(s)?	Satisfactory
Is safety documentation available (Written Safety Programs, SDS, Tailgate Meetings)	Satisfactory
Is drinking water and shade set up sufficient for the amount of workers?	Satisfactory
Are emergency and labor law postings in place?	Satisfactory
Is Personal Protective Equipment being worn as required?	Satisfactory
Are scaffolding safety procedures being followed?	Satisfactory
Are hand and power tools being used safely?	Satisfactory

Is good housekeeping being maintained?	Satisfactory
Is fall protection in place where required?	Unsatisfactory
Comment	
Am drywall removed safety rails for scaffold set up. They have been notified to have them reinstalled asap	-
Is trenching & excavation work being done safely?	Satisfactory
Are confined space safety procedures being followed?	Satisfactory
Are scissor lifts / elevated platforms being used safely?	N/A
Are boom lifts and other aerial devices being used safely?	N/A
Is heavy equipment being used safely?	N/A
Are electrical items being used safely?	Satisfactory
Are roofing operations being performed safely?	Satisfactory
Is demolition work being done safely?	Satisfactory
Are all other tasks being performed safely?	Satisfactory
Any other items?	Satisfactory