



PROJECT INSPECTION

Generated by Safety Compliance App www.safetycompliance.com | www.safetycomplianceapp.com

Company	Woodside Homes: Southern California	Type of Inspection:	General Construction
Project	Blossom	Date of Inspection	May 10, 2024
Inspector Name	Colt Walters	Time of Inspection	12:33 PM


NOTES

19 Items Inspected	16 Satisfactory	1 Unsatisfactory	2 N/A
-----------------------	--------------------	---------------------	----------

INSPECTION ITEMS

General

Is emergency equipment available, including first aid kit(s) and fire extinguisher(s)? **Unsatisfactory**

Comment	
Fire extinguisher not within 10' of gas powered compressor.	

Is safety documentation available (Written Safety Programs, SDS, Tailgate Meetings) **Satisfactory**

Is drinking water and shade set up sufficient for the amount of workers? **Satisfactory**

Are emergency and labor law postings in place? **Satisfactory**

Is Personal Protective Equipment being worn as required? **Satisfactory**

Are scaffolding safety procedures being followed?	Satisfactory
Are hand and power tools being used safely?	Satisfactory
Is good housekeeping being maintained?	Satisfactory
Is fall protection in place where required?	Satisfactory
Is trenching & excavation work being done safely?	Satisfactory
Are confined space safety procedures being followed?	Satisfactory
Are scissor lifts / elevated platforms being used safely?	N/A
Are boom lifts and other aerial devices being used safely?	Satisfactory
Is heavy equipment being used safely?	Satisfactory
Are electrical items being used safely?	Satisfactory
Are roofing operations being performed safely?	Satisfactory
Is demolition work being done safely?	N/A
Are all other tasks being performed safely?	Satisfactory
Any other items?	Satisfactory